



---

Climatec Windows Ltd  
11-14 Fletchers Square  
Temple Farm Industrial Estate  
Southend-on-Sea, Essex

14

---

## EN 14351 - 1:2006 + A1: 2010 Annex ZA

REHAU Total70 Residential & Double Doors  
CLI REH D 002/1  
Ability to Release External Pedestrian Doors in Escape Routes

---

Dangerous Substances	None
Load Bearing Capacity Safety Device	Pass
Thermal Transmittance	<4.7
Ability to release	Pass

---